



FREDERICK COUNTY GOVERNMENT

DIVISION OF FINANCE

Erin M. White, CPA, Acting Director

Department of Procurement & Contracting

Diane George, CPPB, Director

Winchester Hall, 12 East Church Street
Frederick, Maryland 21701

www.FrederickCountyMD.gov

O: 301-600-1069 F: 301-600-2521

Commissioners

Blaine R. Young
President

C. Paul Smith
Vice President

Billy Shreve
David P. Gray
Kirby Delauter

Lori L. Depies, CPA
County Manager

May 22, 2014

IFB No. 14-116

**COURT HOUSE AND PUBLIC SAFETY TRAINING CENTER SECURITY IMPROVEMENTS: FURNISH AND
INSTALL BLAST RESISTANT FILM
Addendum No. 2**

This addendum contains revisions, clarifications, and information pertinent to the IFB for the referenced project and shall supplement, amend, and become part of the IFB for the title project and contract. All bids shall be based on this Addendum, in accordance with the IFB documents.

Acknowledgment of this addendum shall be submitted with the bid, including addendum number and date. Failure to acknowledge addendum may subject the contractor to disqualification.

Clarifications:

1. Neither Bid nor Performance Bonds are required for this project. (See also Changes to Specifications Item 1 below).
2. The correct attachment numbers for response to Question 2 in Addendum 1 are Attachment 2 for the Court House and Attachment 3 for the Public Safety Training Center.
3. There are several areas at the Court House that will require supplemental anchoring on the treated windows. The County is working to revise the specifications related to this work and will publish another addendum as soon as the information is developed. The future addendum may cause the County to extend the bid due date. Any such extension will be identified in the future addendum.

Changes to Specifications:

1. Document D Submission Requirements Section 4 Bid Deposit - **DELETE** Section 4 Bid Deposit in its entirety.
2. Document C Specification Section 16 Technical Specifications – Public Safety Training Center – **DELETE** the third bullet in Section 16.8.2 (“Supplemental anchoring devices...”) in its entirety.
3. **DELETE** Addendum 1 Changes to Specifications Item 2 related to Section 15 Technical Specifications – Court House in its entirety and **REPLACE** it with
 - Wet glaze with structural silicone sealant, applied to four (4) sides, of all windows, operable and non-operable.

4. **DELETE** Addendum 1 Changes to Specifications Item 3 related to Section 16 Technical Specifications – Public Safety Training Center in its entirety and **REPLACE** it with
- Wet glaze with structural silicone sealant, applied to four (4) sides, of all windows, operable and non-operable.

Questions:


1. Question: Addendum #1, Changes to Specification, paragraph 2 and 3 – States that wet glaze with structural silicone sealant applied to 4 sides of operable windows. Does this mean that the only windows receiving the wet glaze are the operable windows, or are all windows to receive 4 sided wet glaze? Is four-sided attachment required?

Answer: See revisions to specifications identified in Items 2, 3, and 4 of Changes to Specifications above.

Attachments:

NONE.

Except as noted herein, all terms and conditions of the document referenced, as heretofore changed, remain unchanged and in full force and effect.



Bruce Johnson
Project Manager IV